



Lead and Copper 90th Percentile Calculation

SOUTH PYMATUNING

PWSID: 6430077

Required:	10	Collected:	15
Last Sample Date:	9/18/2013	Mon. Period:	010113 to 123113
Monitoring Reason:	Routine	Sample Type:	Distribution
Pb90th% (mg/L):	0.005	Cu90th%(mg/L):	0.43

Sample #	Lead (mg/L)	Copper (mg/L)	Pb _{90th%} (mg/L)	Cu _{90th%} (mg/L)
1	0	0		
2	0	0		
3	0	0		
4	0	0		
5	0	0		
6	0	0		
7	0	0.1		
8	0	0.13		
9	0	0.18		
10	0	0.28		
11	0	0.32		
12	0.0022	0.34		
13	0.0045	0.38		
14	0.0057	0.48		
15	0.013	0.74	0.005	0.43

NOTES:

- 1) Results Ranked Lowest to Highest (ND = 0)
- 2) Report 90th percentile result (For 5 samples - take AVG of "4th and 5th")
- 3) Interpolate results for 90th percentile samples that fall between whole numbers